

# Portable Appliance Inspection and Test Record

REPORT NO.

10395

**COMPANY NAME & SITE ADDRESS:**

HODGE  
SELF CATERING UNIT UPPER WOODSOEN AUTERMOY ROAD SKASGAO 9668AN

**CONTRACTOR'S DETAILS**

ORION SECURITY & ELECTRICAL

**TEST EQUIPMENT:**  
Make, Model and Serial Number

TIS 600 MCCCO 13447

**COMPETENT PERSON**

NAME (BLOCK CAPITALS)  
GERY SHARPE

**SIGNATURE**

*[Signature]*

Site	Appliance Description	Appliance No.	VISUAL CHECKS				ELECTRICAL TESTS				Comments	Date of Test	Pass (P) or Fail (F)	
			Class (I, II, etc)	Fuse Rating (A)	Plug	Pass / Fail (✓/X)	Earth Bond Test Current (A)	Resistance (Ω)	Insulation MQ	Functional / Load Test KA				Sub Leakage
	FRIDGE-FREEZER	116	A	13	V	V	230	00.00	19.99	00.10	✓		11/9/2025	P
	KETTLE	117	A	13	V	V	230	00.00	19.99	00.10	✓		11/9/2025	P
	MICROWAVE	118	A	13	V	V	230	00.00	19.99	00.10	✓		11/9/2025	P
	TOASTER	119	A	13	V	V	230	00.00	19.99	00.10	✓		11/9/2025	P
	MOTORISED BED	120	A	13	V	V	230	00.00	19.99	00.10	✓		11/9/2025	P
	WASHING MACHINE	121	A	13	V	V	230	00.00	19.99	00.10	✓		11/9/2025	P
	IRON	122	A	13	V	V	230	00.00	19.99	00.10	✓		11/9/2025	P
	KAMP	123	A	13	V	V	230	00.00	19.99	00.10	✓		11/9/2025	P
	HAVER	124	A	13	V	V	230	00.00	19.99	00.10	✓		11/9/2025	P
	TV	125	A	13	V	V	230	00.00	19.99	00.10	✓		11/9/2025	P
	EXT. LAMP	126	A	13	V	V	230	00.00	19.99	00.10	✓		11/9/2025	P
	META-MIRROR	127	A	13	V	V	230	00.00	19.99	00.10	✓		11/9/2025	P

1710



# ELECTRICAL INSTALLATION CONDITION REPORT

### SECTION A. DETAILS OF THE CLIENT / PERSON ORDERING THE REPORT

Name Vin Jones  
 Address UPLEN WOOD BURN COTTAGES, UPLEN WOOD BURN, MILTON OF CAMPSIE  
 Post Code G66 8AH

### SECTION B. REASON FOR PRODUCING THIS REPORT

Date(s) on which inspection and testing was carried out 11/9/23 **PREMISES BEING LET OUT**

### SECTION C. DETAILS OF THE INSTALLATION WHICH IS THE SUBJECT OF THIS REPORT

Occupier  
 Address LODGE, UPLENWOOD BURN RD, MILTON OF CAMPSIE  
 Post Code G66 8AH

Description of premises (tick as appropriate)  
 Domestic  Commercial  Industrial  Other (include brief description)   
 Estimated age of wiring system 30 years  
 Evidence of additions / alterations Yes  No  Not apparent  if yes estimate age \_\_\_\_\_ years  
 Installation records available? (Regulation 621.1) Yes  No  Date of last inspection UNKNOWN (date)

### SECTION D. EXTENT AND LIMITATIONS OF INSPECTION AND TESTING

Extent of the electrical installation covered by this report  
ELECTRICAL TESTING ON CIRCUITS, VISUAL CHECK ON ACCESSORIES, 25% OF CONNECTIONS CHECKED  
 Agreed limitations including the reasons (see Regulation 634.2) NO LIFTING OF FLOORBOARDS OR CARPETS NO MOVING OF WHITE GOODS  
 Agreed with:  
 Operational limitations including the reasons (see page no \_\_\_\_\_) NONE

The inspection and testing detailed in this report and accompanying schedules have been carried out in accordance with BS 7671: 2008 (ET Wiring Regulations) as amended to 2023  
 It should be noted that cables concealed within trunking and conduits, under floors, in roof spaces, and generally within the fabric of the building or underground, have not been inspected unless specifically agreed between the client and inspector prior to the inspection.

### SECTION E. SUMMARY OF THE CONDITION OF THE INSTALLATION

General condition of the installation (in terms of electrical safety) INSTALL IN GOOD CONDITION

Overall assessment of the installation in terms of its suitability for continued use  
 SATISFACTORY / UNSATISFACTORY\* (Delete as appropriate)  
 \*An unsatisfactory assessment indicates that dangerous (code C1) and/or potentially dangerous (code C2) conditions have been identified.

### SECTION F. RECOMMENDATIONS

Where the overall assessment of the suitability of the installation for continued use above is stated as UNSATISFACTORY, I / we recommend that any observations classified as 'Danger present' (code C1) or 'Potentially dangerous' (code C2) are acted upon as a matter of urgency. Investigation without delay is recommended for observations identified as 'further investigation required'. Observations classified as 'Improvement recommended' (code C3) should be given due consideration.

Subject to the necessary remedial action being taken, I / we recommend that the installation is further inspected and tested by 11/9/28 (date)

### SECTION G. DECLARATION

I/We, being the person(s) responsible for the inspection and testing of the electrical installation (as indicated by my/our signatures below), particulars of which are described above, having exercised reasonable skill and care when carrying out the inspection and testing, hereby declare that the information in this report, including the observations and the attached schedules, provides an accurate assessment of the condition of the electrical installation taking into account the stated extent and limitations in section D of this report.

Inspected and tested by:	Report authorised for issue by:
Name (Capitals) <u>BONA CHALC</u>	Name (Capitals) <u>BONA CHALC</u>
Signature <u>[Signature]</u>	Signature <u>[Signature]</u>
For/on behalf of <u>V. Jones</u>	For/on behalf of <u>V. Jones</u>
Position <u>APPROVED ELECTRICIAN</u>	Position <u>APPROVED ELECTRICIAN</u>
Address <u>77 CAMPSIE RD</u>	Address <u>77 CAMPSIE RD</u>
Post code <u>G61 1HB</u>	Post code <u>G61 1HB</u>
Date <u>11/9/23</u>	Date <u>11/9/23</u>

### SECTION H. SCHEDULE(S)

2 schedule(s) of inspection and 1 schedule(s) of test results are attached  
 The attached schedule(s) are part of this document and this report is valid only when they are attached to it







GENERIC SCHEDULE OF TEST RESULTS

DB reference no: LD 66  
 Location: HALL CORRIDORS  
 Zs at DB (Ω): 0.36  
 I<sub>n</sub> at DB (kA): 0.69  
 Correct supply polarity confirmed:   
 Phase sequence confirmed (where appropriate):

Details of circuits and/or installed equipment vulnerable to damage when testing: None

Details of test instruments used (state serial and/or asset numbers):  
 Continuity: PCU 5  
 Insulation resistance: MULTI  
 Earth fault loop impedance: FUNCTION  
 RCD: FUNCTION  
 Earth electrode resistance: FUNCTION

Tested by: S. Bohm Gentic  
 Name (Capitals): S. Bohm Gentic  
 Signature: [Signature]  
 Date: 11/9/23

Circuit number	Circuit Description	Overcurrent device				Conductor details				Ring final circuit continuity (Ω)			Continuity (R <sub>1</sub> + R <sub>2</sub> ) or R <sub>e</sub>		Insulation Resistance (MΩ)		Polarity	Z <sub>s</sub> (Ω)	RCD (ms)		Test button / functionality	Remarks (continue on a separate sheet if necessary)
		BS (EN)	Type	rating (A)	breaking capacity (kA)	Reference Method	Live (mm <sup>2</sup> )	cpc (mm <sup>2</sup> )	r <sub>1</sub> (line)	r <sub>2</sub> (neutral)	r <sub>2</sub> (cpc)	R <sub>1</sub>	R <sub>2</sub>	Live-Live	Live-Neutral	1			2	3		
1	Tower NAL	60898	B	6	6	C	2.5	1.5	/	/	/	/	/	/	/	/	/	0.66	36.7	4.4	/	INS 30mA
2	U/STAIR Sockets.	60898	B	32	6	C	2.5	1.5	/	/	/	/	/	/	/	/	/	0.54	36.7	4.4	/	
3	M/CHOR Sockets	60898	B	32	6	C	2.5	1.5	/	/	/	/	/	/	/	/	/	0.53	36.7	4.4	/	
4	Coorren	60898	T	32	6	C	6	2.5	/	/	/	/	/	/	/	/	/	0.48	36.7	4.4	/	
5	LCHTS	60898	B	6	6	C	1.5	1.0	/	/	/	/	/	/	/	/	/	0.81	6.4	31.6	/	INS 27mA
6	LCHTS	60898	B	6	6	C	1.5	1.0	/	/	/	/	/	/	/	/	/	0.84	/	/	/	
7	LCHTS	60898	B	6	6	C	1.5	1.0	/	/	/	/	/	/	/	/	/	0.94	7.8	36.2	/	INS 24mA

\* Where there are no spurs connected to a ring final circuit this value is also the (R<sub>1</sub> + R<sub>2</sub>) of the circuit.



**CONDITION REPORT INSPECTION SCHEDULE FOR DOMESTIC AND SIMILAR PREMISES WITH UP TO 100 A SUPPLY**

*Note: This form is suitable for many types of smaller installation not exclusively domestic.*

OUTCOMES	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Not verified	N/V	Limitation	LIM	Not applicable	N/A
ITEM NO	DESCRIPTION						OUTCOME (Use codes above. Provide additional comment where appropriate. C1, C2 and C3 coded items to be recorded in Section K of the Condition Report)				Further investigation required? (Y or N)	
<b>1.0</b>	<b>DISTRIBUTOR'S / SUPPLY INTAKE EQUIPMENT</b>											
1.1	Service cable condition						✓					
1.2	Condition of service head						✓					
1.3	Condition of tails - Distributor						✓					
1.4	Condition of tails - Consumer						✓					
1.5	Condition of metering equipment						✓					
1.6	Condition of isolator (where present)						n/a					
<b>2.0</b>	<b>PRESENCE OF ADEQUATE ARRANGEMENTS FOR OTHER SOURCES SUCH AS MICROGENERATORS (551.6; 551.7)</b>											
<b>3.0</b>	<b>EARTHING / BONDING ARRANGEMENTS (411.3; Chap 54)</b>											
3.1	Presence and condition of distributor's earthing arrangement (542.1.2.1; 542.1.2.2)						✓					
3.2	Presence and condition of earth electrode connection where applicable (542.1.2.3)						n/a					
3.3	Provision of earthing / bonding labels at all appropriate locations (514.13)						✓					
3.4	Confirmation of earthing conductor size (542.3; 543.1.1)						✓					
3.5	Accessibility and condition of earthing conductor at MET (543.3.2)						✓					
3.6	Confirmation of main protective bonding conductor sizes (544.1)						✓					
3.7	Condition and accessibility of main protective bonding conductor connections (543.3.2; 544.1.2)						✓					
3.8	Accessibility and condition of all protective bonding connections (543.3.2)						✓					
<b>4.0</b>	<b>CONSUMER UNIT(S) / DISTRIBUTION BOARD(S)</b>											
4.1	Adequacy of working space / accessibility to consumer unit / distribution board (132.12; 513.1)						✓					
4.2	Security of fixing (134.1.1)						✓					
4.3	Condition of enclosure(s) in terms of IP rating etc (416.2)						✓					
4.4	Condition of enclosure(s) in terms of fire rating etc (526.5)						✓					
4.5	Enclosure not damaged/deteriorated so as to impair safety (621.2(iii))						✓					
4.6	Presence of main linked switch (as required by 537.1.4)						✓					
4.7	Operation of main switch (functional check) (612.13.2)						✓					
4.8	Manual operation of circuit-breakers and RCDs to prove disconnection (612.13.2)						✓					
4.9	Correct identification of circuit details and protective devices (514.8.1; 514.9.1)						✓					
4.10	Presence of RCD quarterly test notice at or near consumer unit / distribution board (514.12.2)						✓					
4.11	Presence of non-standard (mixed) cable colour warning notice at or near consumer unit / distribution board (514.14)						n/a					
4.12	Presence of alternative supply warning notice at or near consumer unit / distribution board (514.15)						n/a					
4.13	Presence of other required labelling (please specify) (Section 514)						n/a					
4.14	Examination of protective device(s) and base(s); correct type and rating (no signs of unacceptable thermal damage, arcing or overheating) (421.1.3)						✓					
4.15	Single-pole protective devices in line conductor only (132.14.1; 530.3.2)						✓					
4.16	Protection against mechanical damage where cables enter consumer unit / distribution board (522.8.1; 522.8.11)						✓					
4.17	Protection against electromagnetic effects where cables enter consumer unit / distribution board / enclosures (521.5.1)						✓					
4.18	RCD(s) provided for fault protection – includes RCBOs (411.4.9; 411.5.2; 531.2)						n/a					
4.19	RCD(s) provided for additional protection - includes RCBOs (411.3.3; 415.1)						n/a C3 SEE PAGE 2					



OUTCOMES	Acceptable condition	✓	Unacceptable condition	State C1 or C2	Improvement recommended	State C3	Not verified	N/V	Limitation	LIM	Not applicable	N/A
ITEM NO	DESCRIPTION						OUTCOME (Use codes above. Provide additional comment where appropriate. C1, C2 and C3 coded items to be recorded in Section K of the Condition Report)				Further investigation required? (Y or N)	
<b>5.0</b>	<b>FINAL CIRCUITS</b>											
5.1	Identification of conductors (514.3.1)						✓					
5.2	Cables correctly supported throughout their run (522.8.5)						N/V - LIM					
5.3	Condition of insulation of live parts (416.1)						✓					
5.4	Non-sheathed cables protected by enclosure in conduit, ducting or trunking (521.10.1)						N/A					
	▪ To include the integrity of conduit and trunking systems (metallic and plastic)						N/A					
5.5	Adequacy of cables for current-carrying capacity with regard for the type and nature of installation (Section 523)						✓					
5.6	Coordination between conductors and overload protective devices (433.1; 533.2.1)						✓					
5.7	Adequacy of protective devices: type and rated current for fault protection (411.3)						✓					
5.8	Presence and adequacy of circuit protective conductors (411.3.1.1; 543.1)						✓					
5.9	Wiring system(s) appropriate for the type and nature of the installation and external influences (Section 522)						✓					
5.10	Concealed cables installed in prescribed zones (see Section D. <i>Extent and limitations</i> ) (522.6.101)						LIM					
5.11	Concealed cables incorporating earthed armour or sheath, or run within earthed wiring system, or otherwise protected against mechanical damage from nails, screws and the like (see Section D. <i>Extent and limitations</i> ) (522.6.101; 522.6.103)						LIM					
5.12	Provision of additional protection by RCD not exceeding 30 mA:						✓					
	▪ for all socket-outlets of rating 20 A or less provided for use by ordinary persons unless an exception is permitted (411.3.3)						✓					
	▪ for supply to mobile equipment not exceeding 32 A rating for use outdoors (411.3.3)						✓					
	▪ for cables concealed in walls or partitions (522.6.102; 522.6.103)						✓					
5.13	Provision of fire barriers, sealing arrangements and protection against thermal effects (Section 527)						LIM					
5.14	Band II cables segregated / separated from Band I cables (528.1)						✓					
5.15	Cables segregated / separated from communications cabling (528.2)						X N/A					
5.16	Cables segregated / separated from non-electrical services (528.3)						✓					
5.17	Termination of cables at enclosures – indicate extent of sampling in Section D of the report (Section 526)						✓					
	▪ Connections soundly made and under no undue strain (526.6)						✓					
	▪ No basic insulation of a conductor visible outside enclosure (526.8)						✓					
	▪ Connections of live conductors adequately enclosed (526.5)						✓					
	▪ Adequately connected at point of entry to enclosure (glands, bushes etc.) (522.8.5)						✓					
5.18	Condition of accessories including socket-outlets, switches and joint boxes (621.2(iii))						✓					
5.19	Suitability of accessories for external influences (512.2)						✓					
<b>6.0</b>	<b>LOCATION(S) CONTAINING A BATH OR SHOWER</b>											
6.1	Additional protection for all low voltage (LV) circuits by RCD not exceeding 30 mA (701.411.3.3)						✓					
6.2	Where used as a protective measure, requirements for SELV or PELV met (701.414.4.5)						N/A					
6.3	Shaver sockets comply with BS EN 61558-2-5 formerly BS 3535 (701.512.3)						N/A					
6.4	Presence of supplementary bonding conductors, unless not required by BS 7671:2008 (701.415.2)						✓					
6.5	Low voltage (e.g. 230 volt) socket-outlets sited at least 3 m from zone 1 (701.512.3)						N/A					
6.6	Suitability of equipment for external influences for installed location in terms of IP rating (701.512.2)						✓					
6.7	Suitability of equipment for installation in a particular zone (701.512.3)						N/A					
6.8	Suitability of current-using equipment for particular position within the location (701.55)						✓					
<b>7.0</b>	<b>OTHER PART 7 SPECIAL INSTALLATIONS OR LOCATIONS</b>											
7.1	List all other special installations or locations present, if any. (Record separately the results of particular inspections applied.)						N/A					

Inspected by: Bonnie Craig Name (Capitals) ..... Signature [Signature] Date: .....



**CONDITION REPORT  
GUIDANCE FOR RECIPIENTS  
(to be appended to the Report)**

**This Report is an important and valuable document which should be retained for future reference.**

1. The purpose of this Condition Report is to confirm, so far as reasonably practicable, whether or not the electrical installation is in a satisfactory condition for continued service (see Section E). The Report should identify any damage, deterioration, defects and/or conditions which may give rise to danger (see Section K).
2. The person ordering the Report should have received the "original" Report and the inspector should have retained a duplicate.
3. The "original" Report should be retained in a safe place and be made available to any person inspecting or undertaking work on the electrical installation in the future. If the property is vacated, this Report will provide the new owner /occupier with details of the condition of the electrical installation at the time the Report was issued.
4. Where the installation incorporates a residual current device (RCD) there should be a notice at or near the device stating that it should be tested quarterly. **For safety reasons it is important that this instruction is followed.**
5. Section D (Extent and Limitations) should identify fully the extent of the installation covered by this Report and any limitations on the inspection and testing. The inspector should have agreed these aspects with the person ordering the Report and with other interested parties (licensing authority, insurance company, mortgage provider and the like) before the inspection was carried out.
6. Some operational limitations such as inability to gain access to parts of the installation or an item of equipment may have been encountered during the inspection. The inspector should have noted these in Section D.
7. For items classified in Section K as C1 ("Danger present"), **the safety of those using the installation is at risk**, and it is recommended that a competent person undertakes the necessary remedial work immediately.
8. For items classified in Section K as C2 ("Potentially dangerous"), **the safety of those using the installation may be at risk** and it is recommended that a competent person undertakes the necessary remedial work as a matter of urgency.
9. Where it has been stated in Section K that an observation requires further investigation the inspection has revealed an apparent deficiency which could not, due to the extent or limitations of the inspection, be fully identified. Such observations should be investigated as soon as possible. A further examination of the installation will be necessary, to determine the nature and extent of the apparent deficiency (see Section F).
10. For safety reasons, the electrical installation should be re-inspected at appropriate intervals by a competent person. The recommended date by which the next inspection is due is stated in Section F of the Report under 'Recommendations' and on a label at or near to the consumer unit / distribution board.

**CONDITION REPORT INSPECTION SCHEDULE  
GUIDANCE FOR THE INSPECTOR**

1. Section 1.0. Where inadequacies in the distributor's equipment are encountered the inspector should advise the person ordering the work to inform the appropriate authority.
2. Older installations designed prior to BS 7671:2008 may not have been provided with RCDs for additional protection. The absence of such protection should as a minimum be given a code C3 classification (item 5.12).
3. The schedule is not exhaustive.
4. Numbers in brackets are Regulation references to specified requirements.